## CITY OF SPRINGFIELD INTER-OFFICE MEMORANDUM

ATTENTION OF FIL	E	DATE	10-20-80
DEPARTMENT			

RE: Gasoline in the Sewer Line - 2600 N. Glenstone

At approximately 7:00 P.M., October 15, 1980, I was notified of a gasoline odor in Wild Bill's Place, 2649 N. Glenstone. Upon arrival at that location, Jim Dancy, of the Fire Department, informed me that the gasoline smell was coming from a Standard Station to the north of Wild Bill's. Apparently the employees at the Standard Station had drained a gasoline tank on a car and let some of it get into the Sanitary Sewer. Mr. Dancy requested that they run water down their sump. The water was allowed to run for approximately 1 hour.

The gasoline smell in Wild Bill's cleared up after ventilating the building for 30 minutes. Also, the manager of Wild Bill's was informed to periodically pour water down their floor drains to keep the traps from going dry.

2649 N. Glanstone

Gene Palest Line tales